



6109 South Don Carlos Dr.  
Taylorsville, Utah 84118

801-403-8803 801-205-9554 Fax: 801-967-5326  
a1environmentalcameron@yahoo.com

## **Addendum 2**

### **ASARCO LAB**

**The transformer must be removed before  
demolition as it contains PCB's**

**This may be the responsibility of Pacific  
Power**

**If not it must be removed by the  
contractor**

**Call Pacific Power for details**